



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2023/359

Dated: 26/05/2023

FIRE SAFETY CERTIFICATE

Certified that the Hansraj Model School, located at Road No-73, Punjabi Bagh, New Delhi-110026, In a building comprised of 03 blocks, Main Block & Yoga block is comprised of basement, ground plus three upper floors, Auditorium block is comprised of Basement, & First floor, and Primary Block is comprised of ground plus two upper floors, Owned/occupied by Hansraj Model School, was issued FSC vide letter No. F6/DFS/MS/School/2020/21 dated 24/01/2020. The premises was re- inspected by the officer concerned by this department on 09/05/2023 in the presence of Sh. Shakeel Ahmad and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by DOE Circular No.- 3298-3398/ NBC Part -IV and that the premises is fit for occupancy class "Educational" Group-B, with effect from 26/05/2023.....for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to the compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 Condition mentioned below.

Issued on 26/05/2023.. at New Delhi.


Atul Garg
Director

Copy to: -

1. The Principal M/s. Hansraj Model School, at Road No-73, Punjabi Bagh, New Delhi-110026.
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Basement shall be used as per building by laws.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. Alternate exit opened at second floor terrace in science block shall not be closed, if it is closed the FSC/NOC will be null & void.